

## **TOWN OF OSWEGO ACTIVITIES THROUGH 10/31/16**

- The Thompson Park Road over Rice Creek was yellow flagged by NYSDOT. Structural fill continues to erode, causing surface settlement and pavement failure. This situation will be monitored and repaired as needed.
- Rathburn Road Bridge. A Draft Engineering Report was delivered and reviewed w/ the Town Board and Highway Superintendent. The report is being finalized with detailed cost and town comments. The final report needs to be forwarded to the NYSDOT upon acceptance by the Town board. This structure was red flagged on October 3, 2016. A plan of action for 2017 replacement is under development between NYSDOT, the Town Highway Department and our office.
- Reviewed meter data on Ontario Heights Sewer District. Only have water meters, nothing on wastewater side. Need to confirm user base, district boundaries, recommend master meter at City line to better track sewage flows and trend leakage. Started weekly monitoring of flow through the lift station to better gage system leakage. Started visual monitoring of flow in the gravity collection system.
- Toured Ontario Heights District with Supervisor, reviewed sewer use ordinance. The “town board designee” has not been appointed for 2016. Historic flow monitoring, ongoing lateral reconstruction, new connections, lift station monitoring are examples of the benefits of this position.
- No word on grant funding requests submitted this year. CFA grant submitted in July for Rt 104 sewer study was a priority project for the Central NY region. Culvert replacement applications were submitted to replace 5 town culverts.