

Town of Oswego Highway Department

Monthly Report – February 12, 2019

- Highway

- Rathburn Bridge over CSX railroad near OCWA. Working to get this bridge turned over to the County for Ownership and Maintenance responsibility. No new information.
- Thompson Rd bridge has been closed until further notice. Seeking input for possible alternatives to full scale replacement. Have met with a company that specializes in these types of repairs using 'Expanding Polymers'. Their product is environmentally neutral and does not contribute to soil and water contamination
- FEMA Damage Description has been agreed upon. Next step will be estimate of costs to repair and/or mitigate. No new information.
- Snow season is finally here. Remember there is no parking on Town roads between November 15 – April 15.
- We are still waiting to see if the County Engineer will be assisting us with the Thompson Rd bridge. No word since the beginning of the month. No new information since last meeting.
- Included is a copy of the incident report regarding Rob Malone and the damaged vehicles on December 24. No new information from the complainants.
- Requesting budget mod for summer paving projects/acceptance of 284 agreement.
-

- BUILDINGS AND GROUNDS

- Town Hall Boiler System

- Boiler #1 found in error @ 2 weeks ago. Hyde Stone could not duplicate the problem or find any issues. Since their visit, boiler has tripped on a daily basis. Hyde -Stone stated they need to 'see it happen' before they can make a repair. *Technician will be making a return trip to simulate 'day/night' time clock to try to identify cause of problem.
- Community Center has been winterized, heat lowered. Work will resume in the spring.
-

- SEWER SYSTEMS

- Ontario Heights

- New generator is installed and start up completed with Koehler. Koester has misc. items to complete. Highway Dept. will black top in spring with money held back from both contractors. *Working with Dan Shaver – generator has been found in the "Off" mode several times. May need new circuit board – will be covered under warranty.

- Sleepy Hollow

- A similar pump has been installed, bring the number of working beds back to 2. Plans will have to be developed for long term upgrades and financing.