

# **Town of Oswego Highway Department**

## **Monthly Report – December 10, 2019**

- **Highway**

- All trucks ready for winter. Have received salt from County as per agreement. We have received our 25% share from the County
- We are finishing our tree work with Limbhanger Tree service.
- 

- **BUILDINGS AND GROUNDS**

- **Town Hall**

- Boiler that had been giving us problems has been functioning normally.
- Damper motor over closet door excessively noisy, not functioning properly. H.S. has disconnected, recommends not replacing. Similar problem with another damper in same room.

- **Community Center**

- Carpenter and Electrician has finished their work, waiting for plumbing work
- 

- **SEWER SYSTEMS**

- **Ontario Heights**

- Need new sewer line turned over to Town. There is a valve that needs yearly maintenance – have yet to locate it. Not sure that Newman has done maintenance.

- **Sleepy Hollow**

- Nothing new to report.